

# ENERGY AUDIT REPORT

Pune Vidyarthi Griha's  
**COLLEGE OF ENGINEERING AND TECHNOLOGY & G K PATE (WANI)  
INSTITUTE OF MANAGEMENT,**  
Vidyanagari, Parvati, Pune 411 009



Year: 2024-25

Prepared by:

## ENGRESS SERVICES

Yashashree, 26, Nirmal Bag Society  
Near Muktangan English School, Parvati, Pune 411009  
Phone: 09890444795 Email: [engress123@gmail.com](mailto:engress123@gmail.com)



**REGISTRATION CERTIFICATES: BEE, UDYAM, MEDA, ISO-9001 & 14001:**

**MAHARASHTRA ENERGY DEVELOPMENT AGENCY**  
**Maharashtra Energy Development Agency**  
 (Government of Maharashtra Institution)  
 Aundh Road, Opposite Spicer College Road, Near Commissionerate of Animal Husbandary,  
 Aundh, Pune, Maharashtra-411067  
 Pin No: 020-33009450  
 Email: ee@mahauria.com, Web: www.mahauria.com

ECN/2024-25/CR-02/385 8<sup>th</sup> October, 2024

**CERTIFICATE OF REGISTRATION FOR CLASS 'A'**

We hereby certify that, the firm having following particulars is registered with MAHARASHTRA ENERGY DEVELOPMENT AGENCY (MEDA) under given category as "Energy Planner & Energy Auditor" in Maharashtra for Energy Conservation Programme of MEDA.

**Name and Address of the firm :** M/s Engress Services  
 Yashshree, 26, Nirmal Bag Society,  
 Near Mukangan English School,  
 Parvati, Pune - 411 009.

**Registration Category :** Empanelled Consultant for Energy Conservation Programme for Class 'A'

**Registration Number :** MEDA/ECN/2024-25/Class A/EA-22

- Energy Conservation Programme intends to identify areas where wasteful use of energy occurs and to evaluate the scope for Energy Conservation and take concrete steps to achieve the evaluated energy savings.
- MEDA reserves the right to visit at any time without giving prior information to verify quarterly activities performed by the firm and canceling the registration, if the information is found incorrect.
- This empanelment is valid till 7<sup>th</sup> October, 2026 from the date of registration, to carry out energy audits under the Energy Conservation Programme.
- The Director General, MEDA reserves the right to cancel the registration at any time without assigning any reasons thereof.

General Manager (E.C.)

Regn. No. EA-8192 No.2942

**National Productivity Council**  
 (National Certifying Agency)  
**PROVISIONAL CERTIFICATE**

This is to certify that Mr./Ms. Achyut Yashavant Mehendale  
 son / daughter of Mr. Yashavant  
 has passed the National Certification Examination for Energy Auditors in April - 2007, conducted on behalf of the Bureau of Energy Efficiency, Ministry of Power, Government of India.

He / She is qualified as Certified Energy Manager as well as Certified Energy Auditor.  
 He / She shall be entitled to practice as Energy Auditor under the Energy Conservation Act 2001, subject to the fulfillment of qualifications for the Accredited Energy Auditor and issue of certificate of Accreditation by the Bureau of Energy Efficiency under the said Act.

This certificate is valid till the issuance of an official certificate by the Bureau of Energy Efficiency.

Place : Chennai, India  
 Date : 10<sup>th</sup> August 2007

*Devi Chaitanya*  
 Controller of Examination

भारत सरकार  
 Government of India  
 सूक्ष्म, लघु एवं मध्यम उद्यम मंत्रालय  
 Ministry of Micro, Small and Medium Enterprises

**UDYAM REGISTRATION CERTIFICATE**

**UDYAM REGISTRATION NUMBER** UDYAM-MH-26-0135636

**NAME OF ENTERPRISE** ENGRESS SERVICES

**TYPE OF ENTERPRISE**

S.No.	Classification Year	Enterprise Type	Classification Date
1	2023-24	Micro	03/02/2024
2	2022-23	Micro	26/06/2022
3	2021-22	Micro	27/07/2021

**MAJOR ACTIVITY** SERVICES

**SOCIAL CATEGORY OF ENTREPRENEUR** GENERAL

**NAME OF UNIT(S)**

S.No.	Name of Unit(s)
1	Engress Services

**OFFICIAL ADDRESS OF ENTERPRISE**

Flat/Door/Block No.	26	Name of Premises/ Building	Yashshree
Village/Town	Pune	Block	1
Road/Street/Lane	Lokmanya Nagar/Nirmal Bag Soc	City	Pune
State	MAHARASHTRA	District	PUNE, Pin-411009
Mobile	8767447244	Email:	engress123@gmail.com

**DATE OF INCORPORATION / REGISTRATION OF ENTERPRISE** 13/04/2021

**DATE OF COMMENCEMENT OF PRODUCTION/BUSINESS** 13/04/2021

**NATIONAL INDUSTRY CLASSIFICATION CODE(S)**

S.No.	NIC 2 Digit	NIC 4 Digit	NIC 5 Digit	Activity
1	70 - Activities of head offices; management consultancy activities	7020 - Management consultancy activities	70200 - Management consultancy activities	Services

**DATE OF UDYAM REGISTRATION** 27/07/2021

*Certificate of Registration*

This is to Certify that  
 Environmental Management System of

**ENGRESS SERVICES**  
 26, YASHASHREE, BLOCK 1, LOKMANYA NAGAR, NIRMAL BAUG SOC,  
 PARVATI, PUNE-411009, MAHARASHTRA, INDIA

has been assessed and found to conform to the requirements of  
**ISO 14001:2015**  
 for the following scope :

CONSULTANCY SERVICES FOR ENERGY AUDIT, GREEN AUDIT & ENVIRONMENTAL AUDIT IN EDUCATIONAL INSTITUTIONS & SUBMISSION OF AUDIT CERTIFICATE AND REPORT.

Certificate No : 23EEKW20  
 Initial Registration Date : 29/03/2023  
 Date of Expiry : 28/03/2026  
 1st Surve. Due : 29/02/2024  
 2nd Surve. Due : 28/02/2025

*Devi Chaitanya*  
 Director

Magnitude Management Services Pvt. Ltd.  
 B-55, Lower Ground Floor, Sector 82, Noida-201301, U.P, India  
 e-mail: info@mmcservices.com, website: www.mmcservices.com  
 \* Subject to successful surveillance audits and case surveillance audits is not allowed to be conducted, this certificate shall be suspended/terminated.

*Certificate of Registration*

This is to Certify that  
 Quality Management System of

**ENGRESS SERVICES**  
 26, YASHASHREE, BLOCK 1, LOKMANYA NAGAR, NIRMAL BAUG SOC, PARVATI,  
 PUNE-411009, MAHARASHTRA, INDIA

has been assessed and found to conform to the requirements of  
**ISO 9001:2015**  
 for the following scope :

CONSULTANCY SERVICES FOR ENERGY AUDIT, GREEN AUDIT & ENVIRONMENTAL AUDIT IN EDUCATIONAL INSTITUTIONS & SUBMISSION OF AUDIT CERTIFICATE AND REPORT.

Certificate No : 23EQK13  
 Initial Registration Date : 27/03/2023  
 Date of Expiry : 26/03/2026  
 1st Surve. Due : 27/02/2024  
 2nd Surve. Due : 27/02/2025

*Devi Chaitanya*  
 Director

Magnitude Management Services Pvt. Ltd.  
 B-55, Lower Ground Floor, Sector 82, Noida-201301, U.P, India  
 e-mail: info@mmcservices.com, website: www.mmcservices.com  
 \* Subject to successful surveillance audits and case surveillance audits is not allowed to be conducted, this certificate shall be suspended/terminated.

## INDEX

Sr. No	Particulars	Page No
I	Acknowledgement	4
II	Executive Summary	5
III	Abbreviations	6
1	Introduction	7
2	Study of Connected Load	8
3	Study of Present Energy Consumption	9
4	Study of Energy Performance Index	10
5	Study of Lighting	11
6	Study of Renewable Energy & Energy Efficiency	13

## **ACKNOWLEDGEMENT**

We Engress Services, Pune, express our sincere gratitude to the management of Pune Vidyarthi Griha's College of Engineering and Technology & G K Pate (Wani) Institute of Management, Vidyanagari, Parvati, Pune 411 009 for awarding us the assignment of Energy Audit of their Campus for the Year: 2024-25.

We are thankful to all the staff members for helping us during the field study.

## EXECUTIVE SUMMARY

1. Pune Vidyarthi Griha's College of Engineering and Technology & G K Pate (Wani) Institute of Management, Pune consumes Energy in the form of **Electrical Energy**: used for various Equipment & other facilities.

### 2. Study of Connected Load & Present Energy Consumption:

No	Particulars	Value	Unit
1	Total Connected Load	227	kW
2	Annual Energy Purchased	234068	kVAh

### 3. Per Capita Energy Consumption:

No	Particulars	Value	Unit
1	Total Annual Energy Purchased	234068	kVAh
2	No of students studying in the College	2536	Nos
3	Per Capita Energy Consumption = (1) / (2)	92.30	kVAh/Annum

### 4. Study of % Usage of LED Lighting:

No	Particulars	Value	Unit
1	Lighting Power Density	8	W/m <sup>2</sup>
2	% of Usage of LED Lighting to Total Lighting Load	31.23	%

### 5. Renewable Energy & Energy Efficiency Projects:

- Usage of Energy Efficient LED fittings
- Usage of BEE STAR Rated Equipment
- Installation of **5 kWp** Roof Top Solar PV Vehicle Charging Station
- Sensor Based Light Operation in Wash Rooms
- Started Energy Club in the College
- Partnering with Energy Swaraj Foundation

### 6. Assumptions:

1. Emission Fator of Electricity: **0.93 Kg of CO<sub>2</sub> / kWh**
2. CO<sub>2</sub> Emissions are computed For **Scope-2**
3. CO<sub>2</sub> Emissions are computed based on Electrical Energy purchased

### 7. References:

- Audit Methodology: [www.mahaurja.com](http://www.mahaurja.com)
- Energy Conservation Building Code: ECBC-2017: [www.beeindia.gov.in](http://www.beeindia.gov.in)
- For CO<sub>2</sub> Emission Factors: [www.ccd.qujarat.gov.in](http://www.ccd.qujarat.gov.in)

## **ABBREVIATIONS**


LED	:	Light Emitting Diode
MSEDCL	:	Maharashtra State Electricity Distribution Company Limited
IQAC	:	Internal Quality Assurance Cell
BEE	:	Bureau of Energy Efficiency
FTL	:	Fluorescent Tube Light
CFL	:	Compact Fluorescent Light
PV	:	Photo Voltaic
Kg	:	Kilo Gram
kWh	:	kilo-Watt Hour
CO <sub>2</sub>	:	Carbon Di Oxide
MT	:	Metric Ton

# CHAPTER-I INTRODUCTION

## 1.1 Introduction:

An Energy Audit is conducted at Pune Vidyarthi Griha's College of Engineering and Technology & G K Pate (Wani) Institute of Management, Vidyanagari, Parvati, Pune 411 009.

## 1.2 Key Study Points:



## 1.3 College Location Image:




## CHAPTER-II STUDY OF CONNECTED LOAD

In this Chapter we present the major contributors to the connected load.

**Table No 1: Study of Equipment wise Connected Load:**

No	Equipment	Qty	Load, W/Unit	Load, kW
1	40 W FTL Fitting	600	40	24
2	20 W LED Fitting	512	20	10.24
3	16 W LED Fitting	33	16	0.528
4	11 W LED Fitting	12	11	0.132
5	Ceiling Fan	426	65	27.69
6	W/M Fan	5	52	0.26
7	Exhaust Fan	49	52	2.548
8	PC	513	150	76.95
9	Printer	14	175	2.45
10	A C	36	1800	64.8
11	Lift	1	3730	3.73
12	Water Pump	1	5968	5.968
13	Other Equipment	50	150	7.5
<b>14</b>	<b>Total</b>			<b>227</b>

**Chart No 1: Study of Connected Load:**




### CHAPTER-III STUDY OF PRESENT ENERGY CONSUMPTION

In this chapter, we present the analysis of Energy Consumption of the College.

**Table No 2: Study of Energy Consumption: 2024-25:**

No	Month	Energy Consumed, kVAh	CO2 Emissions, MT
1	Apr-24	29566	26.61
2	May-24	18096	16.29
3	Jun-24	15038	13.53
4	Jul-24	19896	17.91
5	Aug-24	20482	18.43
6	Sep-24	21398	19.26
7	Oct-24	22798	20.52
8	Nov-24	15098	13.59
9	Dec-24	15104	13.59
10	Jan-25	17106	15.40
11	Feb-25	18086	16.28
12	Mar-25	21400	19.26
13	Total	234068	210.66
14	Maximum	29566	26.61
15	Minimum	15038	13.53
16	Average	19505.67	17.56

**Chart No 2: To study the variation of Monthly Electrical Energy Consumption:**



## **CHAPTER-IV**

### **STUDY OF PER CAPITA ENERGY CONSUMPTION**

**Per Capita Energy Consumption Index:** Per Capita Energy Consumption Index of an educational College/College is its Annual Energy Consumption in Kilo Watt Hours per student studying in the College/College.

It is determined by:

$$\text{Per Capita Energy Consumption Index} = \frac{\text{Annual Energy Consumption in kWh}}{\text{(Total No of students studying)}}$$

**Table No 3: Computation of Per Capita Energy Consumption Index:**

<b>No</b>	<b>Particulars</b>	<b>Value</b>	<b>Unit</b>
1	Total Annual Energy Purchased	<b>169575</b>	kVAh
2	No of students studying in the College		Nos
3	Per Capita Energy Consumption = (4) / (5)		kWh/Annum

## CHAPTER-V STUDY OF LIGHTING

### Terminology:

**1. Lumen** is a unit of light flow or luminous flux. The lumen rating of a lamp is a measure of the total light output of the lamp. The most common measurement of light output (or luminous flux) is the lumen. Light sources are labeled with an output rating in lumens.

**2. Lux** is the metric unit of measure for illuminance of a surface. One lux is equal to one lumen per square meter.

**3. Circuit Watts** is the total power drawn by lamps and ballasts in a lighting circuit under assessment.

**4. Installed Load Efficacy** is the average-maintained illuminance provided on a horizontal working plane per circuit watt with general lighting of an interior. Unit: lux per watt per square metre (lux/W/m<sup>2</sup>)

**5. Lamp Circuit Efficacy** is the amount of light (lumens) emitted by a lamp for each watt of power consumed by the lamp circuit, i.e. including control gear losses. This is a more meaningful measure for those lamps that require control gear. Unit: lumens per circuit watt (lm/W)

**6. Lighting Power Density:** It is defined as Total Lighting Load in a room divided by the Area of that Room in square meters.

In this Chapter we compute the Lighting Power density and the percentage usage of LED Lighting to total Lighting Load of the College.

**Table No 4: Computation of Lighting Power Density: R-412:**


No	Particulars	Value	Unit
1	Qty of 40 W Fittings in Room No: 412	16	Nos
2	Load of 40 W Fitting	40	W/unit
3	Total Load of 16 Nos, 40 W Fittings	<b>640</b>	W
4	Built up area of Class Room: GF-07	<b>80</b>	m <sup>2</sup>
5	<b>Lighting Power Density = (3)/(4)</b>	<b>8</b>	W/m <sup>2</sup>

**Table No 5: Percentage Usage of LED Lighting to Total Lighting Load:**

No	Particulars	Value	Unit
1	No of 40 W FTL Fittings	600	Nos
2	Load per Unit of 40 W FTL Fitting	40	W/unit
3	Total Load of 40 W FTL Fittings	24	kW
4	No of 20 W LED Fittings	512	Nos
5	Load per Unit of 20 W LED Fitting	20	W/unit
6	Total Load of 20 W LED Fittings	10.24	kW
7	No of 16 W LED Fittings	33	Nos
8	Load per Unit of 16 W LED Fitting	16	W/unit
9	Total Load of 16 W LED Fittings	0.528	kW
10	No of 11 W LED Fittings	12	Nos
11	Load per Unit of 11 W LED Fitting	11	W/unit
12	Total Load of 11 W LED Fittings	0.132	kW
13	Total LED Lighting Load= 6+9+12	10.9	kW
14	Total LED Lighting Load= 3+6+9+12	34.9	kW
15	<b>% of LED to Total Lighting Load=13*100/14</b>	<b>31.23</b>	<b>%</b>

## CHAPTER-VI STUDY OF RENEWABLE ENERGY & ENERGY EFFICIENCY

### Usage of Renewable Energy & Energy Conservation Projects:

No	Head	Observation	Photograph
1	Usage of Renewable Energy	Installation of 5 kWp Solar PV based Vehicle Charging Station	<p style="text-align: center;"><b>Solar PV Based Vehicle Charging Station:</b></p> 
2	Energy Conservation Projects	Usage of LED Tubes, STAR Rated ACs	<p style="text-align: center;"><b>LED Tube</b></p> 